
Technical data sheet Cable tray DKS 60 A4

Item number: 6085673





DKS 60 = perforated cable tray system with 60 mm side height.
Permeable cable tray system to VdS guideline 2092 with 30% hole surface for use under sprinkler systems.

Bottom penetration from width 200 mm.

Connecting parts should be ordered in the appropriate quantity.

Magnetic shield insulation without cover 20 dB, with cover 50 dB.

A4 Sta

Stainless steel

2B

Bright, treated

Master data

Item number	6085673
Туре	DKS 630 A4
Description 1	Cable tray DKS
Description 2	perforated w/ floor penetrat.
Manufacturer	ОВО
Dimension	60x300x3000
Material	Stainless steel
Surface	Bright, treated
Surface standard	
Smallest sales unit	3
Unit of quantity	Metre
Weight	215.633 kg
Weight unit	kg/100 m


Technical data sheet

Cable tray DKS 60 A4

Item number: 6085673



Dimensions		
12	Length	3,000 mm
	Length	10 ft
	Width	300 mm
	Width	12 in
	Height	60 mm
	Height	2 in
В	Plate thickness	0.8 mm
	Dimension B	300 mm



Technical data

Connector version	Without connectors
Mounting system fastening type	Floor Ceiling Wall
Walkable	no
Maintain electrical functions	no
With cover	no
Mounting perforation in base	yes
NATO hole pattern	no
Usable cross-section	178 cm ²
Usable cross-section	17800 mm²
Rustproof steel, pickled	no
Side perforation	yes
Wide-span version	no
Load test type according to IEC 61537	Type II
Type of connector, cable support system	Screwed

Technical data sheet Cable tray DKS 60 A4

Item number: 6085673



Loads		
	Insertable support spacings, min.	1.5 m
	Insertable support spacings, max.	2.5 m
	Support spacing 1.5 m	1 kN/m
	Support spacing 1.75 m	0.8 kN/m
	Support spacing 2.0 m	0.5 kN/m
	Support spacing 2.5 m	0.35 kN/m

Load diagram, cable tray, type DKS 60 VA



- 15

Support width in m



Rail bend in mm at permitted kN/m



2


Permitted cable tray/ladder load in kN/m without man load



Load curve with cable tray/ladder width in mm



Strut bend curve according to support width



2,50

2,00

1,50

Load scheme during testing