



A P P R O V A L S ®

Certificate of Suitability

* Addendum *

Certificate No.: SAA192947

Date of Issue: 11 December 2019

Class Description: Non-Prescribed

Product Description: Surge Protection Device

Additional Models	Trade Name	Rating
V50-3-280	OBO BETTERMANN	Uc (50/60Hz) L-N: 280Vac; Iimp L-N 12.5kA; In L-N: 30kA; Up L-N: ≤1.3kV; T1 T2;
V50-3-320	OBO BETTERMANN	Uc (50/60Hz) L-N: 320Vac; Iimp L-N 12.5kA; In L-N: 30kA; Up L-N: ≤1.4kV; T1 T2;
V50-3-385	OBO BETTERMANN	Uc (50/60Hz) L-N: 385Vac; Iimp L-N 12.5kA; In L-N: 30kA; Up L-N: ≤1.7kV; T1 T2;
V50-4+FS-280	OBO BETTERMANN	Uc (50/60Hz) L-N: 280Vac; Iimp L-N 12.5kA; In L-N: 30kA; Up L-N: ≤1.3kV; T1 T2;
V50-4-280	OBO BETTERMANN	Uc (50/60Hz) L-N: 280Vac; Iimp L-N 12.5kA; In L-N: 30kA; Up L-N: ≤1.3kV; T1 T2;
V80-0-280	OBO BETTERMANN	Uc (50/60Hz) L-N: 280Vac; Iimp L-N 12.5kA; In L-N: 40kA; Up L-N: ≤1.4kV; T1 T2;
V80-0-385	OBO BETTERMANN	Uc (50/60Hz) L-N: 385Vac; Iimp L-N 12.5kA; In L-N: 40kA; Up L-N: ≤1.8kV; T1 T2;
V80-1+FS-280	OBO BETTERMANN	Uc (50/60Hz) L-N: 280Vac; Iimp L-N 12.5kA; In L-N: 40kA; Up L-N: ≤1.4kV; T1 T2;

For and on Behalf of
SAA Approvals Pty Ltd


SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under *Qld Electrical Safety Act 2002 and Electrical Safety Regulations 2013* certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au

JAS-ANZ



Issued: 11-12-19 192947/6